



NOTE 4

NOTES:

- 1) AC CIRCUIT BREAKER LOCATION IS SHOWN ON THE OUTLINE DRAWING (JE5051-00).
- 2) FLOAT ADJUST POTENTIOMETER LOCATION IS SHOWN ON THE INTERNAL COMPONENT LAYOUT DRAWING (JE5052-00).
- 3) ENGRAVED FUNCTIONAL NAMEPLATES HAVE WHITE LETTERING ON A BLACK BACKGROUND.
- 4) END OF CHARGE TIMER FACTORY SET AT 3 HOURS (PROGRAMMABLE FROM 1 SECOND UP TO 999 HOURS).

3	21309	091108	THIRD ANGLE PROJECTION	1075 Saint John Street Easton, PA 18042-6661 PH 610-330-9000 FAX 610-330-8510 www.hindlepowerinc.com
2	21060	031308		
1	E1700	060704	UNLESS OTHERWISE NOTED DIMENSIONS ARE IN INCHES. TOLERANCES ARE:	TITLE RAILROAD MAINTENANCE CHARGER SERIES: INSTRUMENT PANEL DETAIL
0	E1180	031903		DRAWING No JE5053-00
REV	ECN No	DATE	SCALE NTS	PART No JE5053-00 SHEET 1 OF 1