



USER CONNECTIONS	CONNECTION
TB10 (+)	#6-350 MCM
TB10 (-)	#6-350 MCM
BATT TRMNL (+/-)	#14-3/0 AWG
CHGR TRMNL (+/-)	#14-3/0 AWG
TB1	#22-14 AWG
TB2	#22-14 AWG
TB3	#22-14 AWG
TB4	#22-14 AWG
TB5	#22-14 AWG
TB6	#22-14 AWG

- NOTES:
- TEST LOAD BOX FOR CAPACITY TESTING.
 - BATTERY REMOTE SENSE LEADS FOR ACCURATE VOLTAGE MEASUREMENT.
 - BATTERY CHARGER COMMON ALARM CONNECTION TO BINARY INPUTS FOR MONITORING CHARGER.

REV. 0	DRN BY KJB	CHK BY NCH	APP BY NCH	DATE 12/04/17	DRN BY KJB	DATE: 12/04/17
DESCRIPTION INITIAL RELEASE OF BRUNO SYSTEM APPLICATION DIAGRAM. ECN NO. 26028					CHK BY NCH	DATE: 12/04/17
					APP BY NCH	DATE: 12/04/17
PROPERTY AND CONFIDENTIAL NOTICE ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.					UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS FOLLOW THE ANSI SYSTEM IPS (INCHES-POUNDS & SECONDS) TOLERANCES ARE: FRAC. ±1/64, DEC. ±0.015, ANG ±25°	



HINDLE POWER

TITLE: DWG, CONN. DIAGRAM, BRUNO, SYS, APP w/OPTIONS

DRAWING No: **JE5259-00**

REV 0 **B**

SHEET 1 OF 1

SCALE: NTS