




SEE DRAWING
JE5253-01


NOTE 3

NOTE 5



NOTE 4

NOTE 4



NOTES:

- ENCLOSURE IS A NEMA TYPE 1 / IP20 TOP-VENTED STEEL CABINET WITHOUT GASKETS. FINISH IS ANSI-61 GRAY EPOXY POWDERCOAT. BASE IS 14 GA. SHROUD IS 18 GA. DOOR IS 16 GA.
- ALLOW 6in / 152mm OF FREE AIR ON ALL VENTED SURFACES (TOP, SIDES & REAR) FOR COOLING.
- SIX (6) KEY-HOLE SLOTS ARE PROVIDED ON BACK OF ENCLOSURE AS SHOWN. FOR WALL-MOUNTING WITH 0.25in / 6.25mm HARDWARE.
- SIX (6) 1.31in / 33mm DIA KNOCKOUTS ARE PROVIDED AS SHOWN, WITH TWO (2) ADDITIONAL KNOCKOUTS FEATURED ON BOTTOM PANEL OF ENCLOSURE. USE OF ANY OF THESE FOUR (4) LOWER CONDUIT KNOCKOUTS WILL ALLOW REMOVAL OF CABINET SHROUD WITHOUT REMOVAL OF EXTERNAL WIRING.
- DATA NAMEPLATE DECAL (WITH CHARGER RATINGS) APPLIED TO DOOR.
- BATTERY CHARGER SHIPPING WEIGHT: SEE PRODUCT LITERATURE.

REV. D	DRN BY KJB	CHK BY MCR	APP BY MCR	DATE 12/1/2021	DRN BY KJB	DATE: 1/21/2021
DESCRIPTION STANDARD DRAWINGS.					CHK BY MCR	DATE: 1/21/2021
ECN NO. N/A					APP BY MCR	DATE: 1/21/2021
PROPERTY AND CONFIDENTIAL NOTICE ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.						







TITLE
**ATEVO BATTERY CHARGER
OUTLINE: NEMA-1 STYLE-5054 ENCL
1Ø W/O OPTIONS 6-25A**

B	SCALE NTS	DWG No JE5251-01	REV D	SHEET 1 OF 1
----------	--------------	---------------------	----------	-----------------

DUAL DIMENSIONS in [mm]

SYM	STANDARD COMPONENT DESCRIPTION
A1	MAIN CONTROL PC BOARD
A2	POWER BOARD
A6	RECTIFIER H/S ASSEMBLY
A7	FILTER BOARD (C1x/R9x)
A9	MOV BOARD
CB1	AC INPUT CIRCUIT BREAKER C60-K 2P
CB2	DC OUTPUT CIRCUIT BREAKER C60-K 2P
AUXCB2	DC CKT BKR (CB2) AUXILIARY CONTACTS
L1	MAIN INDUCTOR
L2	FILTER INDUCTOR
T1	POWER ISOLATION TRANSFORMER



NOTES:
1. FOR DETAIL VIEWS OF ALL PC BOARDS (A1, A2, A4 etc.) SEE DRAWING JE5253-01.

I/O TERMINAL	DESCRIPTION - TYPE	CONNECTION
CB2 (+/-)	POS/NEG DC OUTPUT TERMINALS - CKT BREAKER COMPRESSION LUG	#18-4 AWG
GND LUG	USER GROUND TERMINAL - CU-ALUMINUM COMPRESSION LUG	#14-6 AWG
CB1 (L1/L2)	AC INPUT TERMINALS - CKT BREAKER COMPRESSION LUG	#18-4 AWG
(A2) TB1	POS/NEG REMOTE SENSE TERMS (A2) - SOLDERLESS COMP SCREW	#22-14 AWG
(A2) TB8	TEMPCO PROBE (A10) TERM BLK - SOLDERLESS COMP SCREW	#22-14 AWG
(A1) TB6	SUMMARY ALARM TERMINAL BLOCK (A1) - SOLDERLESS COMP SCREW	#22-14 AWG

REV. DRN BY	CHK BY	APP BY	DATE	DRN BY	DATE
D	KJB	MCR	MCR	12/1/2021	1/21/2021
DESCRIPTION			CHK BY	DATE	
STANDARD DRAWINGS.			MCR	1/21/2021	
ECN NO. N/A			APP BY	DATE	
			MCR	1/21/2021	
PROPERTY AND CONFIDENTIAL NOTICE					
ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.					


1075 Saint John Street
Easton, PA 18042-6661
PH 610-330-9000 FAX 610-330-8510
www.hindlepowerinc.com

HINDLEPOWER

ATEVO BATTERY CHARGER
INTERNAL COMPONENT LAYOUT: STYLE-5054
1Ø W/O OPTIONS 6-25A


SCALE DWG No
B NTS JE5252-01

REV SHEET
D 1 OF 1




CONTROL PANEL
(PART No. FK5047-00)

NOTE: ALL ALARM CONTACTS ARE ENERGIZED WHEN IN THE NON-ALARM STATE (FAIL SAFE). ALL ALARM CONTACTS WILL CHANGE STATE WHEN CHARGER IS POWERED DOWN. CONTACT RATING IS 0.5A @ 125VAC/VDC RESISTIVE.



MAIN CONTROL PC BOARD (A1)
FRONT VIEW – FACING CHARGER DOOR WHEN INSTALLED



MAIN CONTROL PC BOARD (A1)
BACK VIEW – FACING CHARGER COMPONENTS WHEN INSTALLED

MAIN CONTROL PC BOARD (A1)

INDICATOR LIGHTS (LEDs):

- LED1 – GREEN – AC ON
- LED2 – RED – HIGH DC VOLTAGE ALARM
- LED3 – RED – LOW DC VOLTAGE ALARM
- LED4 – RED – DC OUTPUT FAILURE ALARM
- LED5 – RED – AC INPUT FAILURE ALARM
- LED6 – RED – POSITIVE (+) GROUND ALARM
- LED7 – RED – NEGATIVE (-) GROUND ALARM
- LED8 – RED – COMMON ALARM
- LED9 – RED – ACTION REQUIRED ALARM
- LED10 – GREEN – HEALTHY OPERATION
- DS1 – RED – HIGH LEVEL SHUTDOWN (HLD)
- DS2 – RED – ANALOG LOW VOLTAGE ALARM (LLD)
- DS3 – RED – MEMORY CARD ACTIVITY

JUMPERS:

- J1 – ANALOG HIGH VOLTAGE SHUTDOWN JUMPER
- J3 – SD CARD PORT
- JP4 – RE-FLASH (FIELD PROGRAMMING) JUMPER
- TERMINAL BLOCKS:
- TB6 – COMMON ALARM RELAY CONTACTS
- TEST POINTS:
- 1.8V – 1.8 VOLTS
- 3.3V – 3.3 VOLTS
- 5V – 5.0 VOLTS
- GND – GROUND
- AGND – ANALOG GROUND
- SDA – MAIN BOARD 12C DATA
- SCL – MAIN BOARD 12C CLOCK

SWITCHES:

- S1 – DISPLAY BUTTON
- S2 – CHARGE MODE BUTTON
- S3 – EQUALIZE METHOD BUTTON
- S4 – ESCAPE (ESC) BUTTON
- S5 – LEFT ARROW BUTTON
- S6 – MENU BUTTON
- S7 – UP ARROW BUTTON
- S8 – EDIT / ENTER BUTTON
- S9 – DOWN ARROW BUTTON
- S10 – ALARM BUTTON
- S11 – RIGHT ARROW BUTTON
- S12 – HINDLE HEALTH (HHS) BUTTON
- SW13 – SYSTEM RESET BUTTON (BACK OF BOARD)

CONNECTORS:

- P1 – POWER BOARD RIBBON
- P2 – 3 PHASE RECTIFIER RIBBON
- P3 – USB EXPANSION PORT
- P4 – SPI & I2C EXPANSION PORT #1
- P5 – SPI & I2C EXPANSION PORT #2
- P6 – DISPLAY SPI PORT
- P7 – DISPLAY JTAG PORTS
- P10 – SERIAL INTERFACE PORT #1
- P11 – SERIAL INTERFACE PORT #2
- P12 – SERIAL INTERFACE PORT #3
- P13 – ETHERNET INTERFACE PORT
- P17 – GENERAL EXPANSION PORT

I/O TERMINAL	DESCRIPTION – TYPE	CONNECTION
(A1) TB6	SUMMARY ALARM TERMINAL BLOCK (A1) – SOLDERLESS COMP SCREW	#22-14 AWG

REV. DRN BY	CHK BY	APP BY	DATE	DRN BY	DATE
D	KJB	MCR	MCR	12/1/2021	1/21/2021
DESCRIPTION			CHK BY	DATE	
STANDARD DRAWINGS.			MCR	1/21/2021	
ECN NO. N/A			APP BY	DATE	
			MCR	1/21/2021	
PROPERTY AND CONFIDENTIAL NOTICE					
ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.					

HINDLEPOWER

1075 Saint John Street
Easton, PA 18042-6661
PH 610-330-9000 FAX 610-330-8510
www.hindlepowerinc.com

TITLE

ATEVO BATTERY CHARGER
CONTROL PANEL / PC BOARD DETAIL
1Ø W/O OPTIONS 6-25A



B SCALE DWG No

NTS

JE5253-01

REV D SHEET 1 OF 2

FILTER BOARD (A7)



- USER TERMINALS ON POWER BOARD (A2):
 TB1 – REMOTE VOLTAGE SENSE
 TB8 – BATTERY TEMPERATURE COMPENSATION
- JUMPERS ON POWER BOARD (A2):
 JP102 – GROUND DETECT CIRCUIT ENABLE / DISABLE
 JP103 – REMOTE OR LOCAL SENSE SELECTOR (+)
 JP104 – REMOTE OR LOCAL SENSE SELECTOR (-)
- CONNECTORS ON POWER BOARD (A2):
 J1 – POWER OUT
 J101 – DC POWER SUPPLY
 J102 – DC POWER SUPPLY
 J105 – AUXILIARY I/O BOARD
 P1 – MAIN CONTROL BOARD RIBBON
- DISCRETE TERMINALS:
 AC MOV – CHASSIS EARTH GROUND
 EARTH – CHASSIS EARTH GROUND (DOOR)
 CB1 – AC BREAKER AUX SWITCH CONTACT
 CB2 – DC BREAKER AUX SWITCH CONTACT
 COMM – BREAKER AUX SWITCH COMMON
 C2+ – ELIMINATOR FILTER CAPACITOR (+)
 C2- – ELIMINATOR FILTER CAPACITOR (-)
 X1 – TRANSFORMER SECONDARY WINDING
 X4 – TRANSFORMER SECONDARY WINDING
 L1-1 – FILTER INDUCTOR #1 (TERMINAL #1)
 L1-2 – FILTER INDUCTOR #1 (TERMINAL #2)
 L2-1 – FILTER INDUCTOR #2 (TERMINAL #1)
 L2-2 – FILTER INDUCTOR #2 (TERMINAL #2)
 TB10 – CB2 DC BREAKER
 TB11 – 'Y' CONTROL WINDINGS
 TBS1 – FILTER CAPACITOR BOARD (+)
 TBS2 – FILTER CAPACITOR BOARD (-)
- TEST POINTS ON POWER BOARD (A2):
 TP1 – PRE-FILTERED DC BUS (-)
 TP2 – PRE-FILTERED DC BUS (+)
 TP3 – DC BUS (-)
 TP4 – DC BUS (+)

I/O TERMINAL	DESCRIPTION - TYPE	CONNECTION
(A2) TB1	POS/NEG REMOTE SENSE TERMS (A2) – SOLDERLESS COMP SCREW	#22-14 AWG
(A2) TB8	TEMPCO PROBE (A10) TERM BLK – SOLDERLESS COMP SCREW	#22-14 AWG


HINDLEPOWER
 1075 Saint John Street
 Easton, PA 18042-6661
 PH 610-330-9000 FAX 610-330-8510
 www.hindlepowerinc.com

TITLE
**ATEVO BATTERY CHARGER
 CONTROL PANEL / PC BOARD DETAIL
 1Ø W/O OPTIONS 6-25A**

B SCALE NTS DWG No **JE5253-01** REV D SHEET 2 OF 2

T1 CONNECTION TABLE	
INPUT	JUMPER
120	H1-H3, H2-H5
208	H4-H2 (2)
240	H3-H2 (2)

SHIPPED FROM
FACTORY
TAPPED FOR




NOTES:

1. FOR PHYSICAL COMPONENT FEATURES OF PC BOARDS (A1, A2, A4, A7 etc.) SEE DETAIL DRAWING JE5253-01.
2. ALL ALARM CONTACTS SHOWN IN NON-ALARM STATE, WITH CHARGER ENERGIZED AND ALARM RELAYS ENERGIZED (FAIL SAFE). ALL ALARM CONTACTS WILL CHANGE STATE WHEN CHARGER IS POWERED DOWN. CONTACT RATING IS: 0.5A @ 125VAC/VDC RESISTIVE.
4. INPUT POWER ISOLATION TRANSFORMER (T1) IS FIELD RE-TAPPABLE FOR 120, 208 OR 240 VAC. SEE TABLE ABOVE.

NOTE 2

REV. D	DRN BY KJB	CHK BY MCR	APP BY MCR	DATE 12/1/2021	DRN BY KJB	DATE: 1/21/2021	<p>1075 Saint John Street Easton, PA 18042-6661 PH 610-330-9000 FAX 610-330-8510 www.hindlepowerinc.com</p>
DESCRIPTION STANDARD DRAWINGS.					CHK BY MCR	DATE: 1/21/2021	
ECN NO. N/A					APP BY MCR	DATE: 1/21/2021	
PROPERTY AND CONFIDENTIAL NOTICE ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.					TITLE ATEVO BATTERY CHARGER SCHEMATIC: STYLE 5070 1φ W/O OPTIONS 6-25A		<p>B SCALE DWG No NTS JE5254-01</p>
					REV D SHEET 1 OF 1		



NOTES:

1. WHEN NATURAL LEADS OF MAGNETICS ARE NOT USED, CHARGER COMPONENTS ARE CONNECTED WITH BLACK FLAME-RETARDANT SWITCHBOARD INSULATION SYSTEM (SIS) TYPE WIRING, IDENTIFIED ON EACH END WITH NUMBER-CODED MARKERS. GROUND WIRES ARE GREEN WITH YELLOW STRIPE.

REV. DRN BY D KJB	CHK BY MCR	APP BY MCR	DATE 12/1/2021	DRN BY KJB	DATE 1/21/2021	<p>HINDLEPOWER</p> <p>1075 Saint John Street Easton, PA 18042-6661 PH 610-330-9000 FAX 610-330-8510 www.hindlepowerinc.com</p>
DESCRIPTION STANDARD DRAWINGS.				CHK BY MCR	DATE 1/21/2021	
ECN NO. N/A				APP BY MCR	DATE 1/21/2021	
PROPERTY AND CONFIDENTIAL NOTICE ANY REPRODUCTION, PARTIAL OR AS A WHOLE OF THIS DOCUMENT WITHOUT THE WRITTEN PERMISSION OF HINDLE POWER, INC IS STRICTLY PROHIBITED.						<p>TITLE ATEVO BATTERY CHARGER CONN DIAGRAM: STYLE 5070 1Ø W/O OPTIONS 6-25A</p>
			<p>SCALE DWG No B NTS JE5255-01</p>		<p>REV SHEET D 1 OF 1</p>	